

APPENDIX C

CROSS CONNECTION CONTROL PLAN

As required by the Colorado Department of Public Health and Environment, the drinking water system has been evaluated in terms of risk posed by hazardous cross connections. The following potential sources of risk have been identified:

1. Boiler
2. Outdoor hose connections

Protections from cross connection contamination have been installed on both potential sources, as follows:

1. Boiler – triple backflow preventer
 2. Outdoor hose connections – vacuum breakers
-